# **SBCC Work Session**

October 19, 2012

# 2012 INTERNATIONAL MECHANICAL CODE

### **PUBLIC TESTIMONY SUMMARY**

Links are provided to written testimony. Links are provided here to minutes for the <u>Sept. 14</u> Public Hearings.

#### **Eric Vander Mey**

Change below is required to correlate with exception to section 403.8.5.1 for intermittent operation.

403.8.2 Control and operation.

5.5 The intermittent mechanical ventilation system shall operate at least one hour out of every twelve four.

### **City of Seattle**

**403.8.5.2** Whole house supply system general requirements. Whole house ventilation systems integrated with a forced-air system, systems using supply fans and systems using a heat or energy recovery ventilation system shall comply with the following.

(Items 1-5 remain as printed)

6. Whole house ventilation controls for intermittent operation shall be provided at both allow concurrent operation of the forced-air fan and the associated outdoor air motorized damper.

EXCEPTION: Engineered central ventilation systems serving dwelling units or sleeping units are not required to have individual controls for each dwelling or sleeping unit when designed for continuous operation and approved by the code official.

7. Whole house ventilation controls for continuous operation shall be provided at the forced-air fan.

EXCEPTION: Engineered central ventilation systems serving dwelling units or sleeping units are not required to have individual controls for each dwelling or sleeping unit when designed for continuous operation and approved by the code official.

403.8.2 (See Eric's comment, above).

303.3 should be numbered 301.3.

<u>928.1</u> The last sentence of item 4 should be a separate item 5.

## **Larry Andrews**

Do not adopt 2012 IMC (Spokane Public Hearing, p. 4)

Add language from 1997 UMC regarding use of unlisted equipment (Spokane, p. 2)

Do not adopt changes to IMC Chapter 10 regarding boilers (Spokane, p. 4)